

Paver Pedestal System 1

Model Code	Height Range	Product Image	Info for Accessories	
CX-MB-T0-A	19-30mm		2mm shim	 x1
			3.5mm Thickness Spacer Tab	 x1
			19mm T-head + 14mm T-Base	 x1
CX-MB-T0-B	28-42mm		2mm shim	 x1
			3.5mm Thickness Spacer Tab	 x1
			26mm T-head + 22mm T-Base	 x1
CX-MB-T0-C	40-65mm		2mm shim	 x1
			3.5mm Thickness Spacer Tab	 x1
			38mm T-head + 33mm T-base	 x1

CX-MB-T0-D	60-105mm		2mm shim	 x1
			3.5mm Thickness Spacer Tab	 x1
			60mm T-head + Fix collar + 53mm T-base	 x1
CX-MB-T0-E	90-185mm		2mm shim	 x1
			3.5mm Thickness Spacer Tab	 x1
			80mm T-head + Fix collar + Adjustment Ring + 75mm T-base	 x1

Technical Test Report

Report ID: JC 2016020117EnR1K1


Test result :

Sample No.	Sample Name	Test Items	Unit	Test Results	Test Standard
2016020117	Adjustable plastic pedestal	Material Qualitative	/	Polypropylene	ASTM D1418-10a
		Hardness	Shore D	35	ASTM D2240-05
		Density	g/cm ³	0.8878	ASTM D792-08
		Melting point	°C	169.20	ASTM D794-01
		Glass-transition temperature	°C	-24.6	ASTM D3418-08

Note:

Test room conditions: Temperature (23±2) °C, Humidity (50±5) %RH.

Sample photo:



****End of Report****